

Laboratory Results

Sample Water Sample ID No.: WW-21 (Revised)
Sample Date: April 17, 2010
SampleType: Domestic drinking water

Laboratory Analyses Performed:

Ammonia, Nitrogen and Nitrate	Pesticides and Herbicides
Pathogens	Trace Organics
General Chemistry	Veterinary Pharmaceuticals
Hormones	Wastewater Pharmaceuticals
Metals	Nitrogen Isotopes
Perchlorate	Sulfur hexafluoride (SF ₆) Age Dating

Chemical	Result ^a	Units	Laboratory Detection Limit	Drinking Water Standards	
				MCL ^b	SMCL ^c
Nitrogen Compounds					
Nitrate (NO₃)	38	mg/L	0.05	10	
Ammonia (NH ₃ +NH ₄) as N	Not Detected	mg/L	0.05		
Nitrate+Nitrite (NO₃+NO₂) as N	40.5	mg/L	2.5	10	
Total Kjeldahl Nitrogen	Not Detected	mg/L	5.1		
Pathogens					
Escherichia coli	Not Detected	#/100 mL	1	See Footnote ^d	
Fecal Coliform	Not Detected	#/100 mL	1	0.0 ^e	
Total Coliform	Not Detected	#/100 mL	1	5% (per month) ^e	
General Chemistry					
Alkalinity as CaCO ₃	178	mg/L	5		
Bromide	0.737	mg/L	0.2		
Chloride	51.2	mg/L	1.2		250
Fluoride	0.462	mg/L	0.04	4.0	2.0
Phosphorus, total	0.101	mg/L	0.02		
Sulfate	164	mg/L	6		250
Hormones^f					
17-a-estradiol	Not Detected	ug/L	0.00021		
17-a-ethynyl-estradiol	Not Detected	ug/L	0.00016		
17-b-estradiol	Not Detected	ug/L	0.00014		
Estriol	Not Detected	ug/L	0.00022		
Estrone	Not Detected	ug/L	0.00021		
Hormones^f					
11-Keto Testosterone	Not Detected	ug/L	0.002		
17a-Hydroxyprogesterone	Not Detected	ug/L	0.002		
17alpha-trenbolone	Not Detected	ug/L	0.002		
17beta-estradiol	Not Detected	ug/L	0.002		
17beta-trenbolone	Not Detected	ug/L	0.002		
4-Androstenedione	Not Detected	ug/L	0.002		
a-Estradiol	Not Detected	ug/L	0.002		
Androstenedione	Not Detected	ug/L	0.002		
Androsterone	Not Detected	ug/L	0.002		
a-Zearalanol	Not Detected	ug/L	0.002		
a-Zearalenol	Not Detected	ug/L	0.002		
b-Zearalanol	Not Detected	ug/L	0.002		

Chemical	Result ^a	Units	Laboratory Detection Limit	Drinking Water Standards	
				MCL ^b	SMCL ^c
b-Zearalenol	Not Detected	ug/L	0.002		
Epitestosterone	Not Detected	ug/L	0.002		
Estriol	Not Detected	ug/L	0.002		
Estrone	Not Detected	ug/L	0.002		
Ethynyl Estradiol	Not Detected	ug/L	0.002		
Melengesterol Acetate	Not Detected	ug/L	0.002		
Progesterone	Not Detected	ug/L	0.002		
Testosterone	Not Detected	ug/L	0.002		
Metals					
Arsenic	Not Detected	ug/L	45	10	
Barium	107	ug/L	1	2000	
Cadmium	Not Detected	ug/L	3	5.0	
Calcium	111000	ug/L	30		
Chromium	Not Detected	ug/L	10	100	
Copper	Not Detected	ug/L	5	1300	1000
Iron	67	ug/L	20		300
Lead	Not Detected	ug/L	25	15	
Magnesium	35700	ug/L	50		
Manganese	3.1	ug/L	2		50
Mercury	Not Detected	ug/L	0.05	2.0	
Potassium	4590	ug/L	700		
Selenium	55	ug/L	50	50	
Silver	Not Detected	ug/L	10		100
Sodium	55800	ug/L	100		
Zinc	Not Detected	ug/L	5		5000
Perchlorate					
Perchlorate	0.978	ug/L	0.003	See Footnote ^g	
Pesticides/ Herbicides					
2,3,4,5-Tetrachlorophenol	Not Detected	ug/L	0.19		
2,3,4,6-Tetrachlorophenol	Not Detected	ug/L	0.094		
2,4,5-T	Not Detected	ug/L	0.47		
2,4,5-Trichlorophenol	Not Detected	ug/L	0.19		
2,4,6-Trichlorophenol	Not Detected	ug/L	0.47		
2,4-D	Not Detected	ug/L	0.47	70.0	
2,4-DB	Not Detected	ug/L	0.094		
3,5-Dichlorobenzoic acid	Not Detected	ug/L	0.094		
4-Nitrophenol	Not Detected	ug/L	0.47		
Acifluorfen	Not Detected	ug/L	0.47		
Alachlor	Not Detected	ug/L	0.094	2.0	
Atrazine	Not Detected	ug/L	0.094	3.0	
Azinphos-methyl	Not Detected	ug/L	0.094		
Bentazon	Not Detected	ug/L	0.094		
Benzonitrile, 2,6-dichloro-	Not Detected	ug/L	0.094		
Bromoxynil	Not Detected	ug/L	0.094		
Chloramben	Not Detected	ug/L	0.19		
Chlorpyrifos, Ethyl	Not Detected	ug/L	0.094		
Clopyralid	Not Detected	ug/L	0.94		
DACTHAL-DCPA	Not Detected	ug/L	0.47		
Diazinon	Not Detected	ug/L	0.094		
Dicamba	Not Detected	ug/L	0.094		

Chemical	Result ^a	Units	Laboratory Detection Limit	Drinking Water Standards	
				MCL ^b	SMCL ^c
Dichlorprop	Not Detected	ug/L	0.47		
Diclofop, Methyl	Not Detected	ug/L	0.094		
Dinoseb	Not Detected	ug/L	0.47	7.0	
Diuron	Not Detected	ug/L	0.094		
Endosulfan I	Not Detected	ug/L	0.094		
Endosulfan II	Not Detected	ug/L	0.094		
Endosulfan Sulfate	Not Detected	ug/L	0.094		
Fenhexamid	Not Detected	ug/L	0.94		
Fenpropathrin	Not Detected	ug/L	0.094		
Imidan	Not Detected	ug/L	0.19		
Ioxynil	Not Detected	ug/L	0.094		
Kresoxim-methyl	Not Detected	ug/L	0.094		
MCPA	Not Detected	ug/L	0.19		
MCPP	Not Detected	ug/L	0.094		
Metribuzin	Not Detected	ug/L	0.094		
Myclobutanil	Not Detected	ug/L	0.094		
Oxyfluorfen	Not Detected	ug/L	0.094		
Pendimethalin	Not Detected	ug/L	0.094		
Pentachlorophenol	Not Detected	ug/L	0.094	1.0	
Picloram	Not Detected	ug/L	0.94	500	
Propargite	Not Detected	ug/L	0.094		
Silvex	Not Detected	ug/L	0.19	50	
Simazine	Not Detected	ug/L	0.09	4.0	
SURFLAN	Not Detected	ug/L	1.9		
Terbacil	Not Detected	ug/L	1.9		
Trichlorpyr	Not Detected	ug/L	0.094		
Triflumizole	Not Detected	ug/L	0.38		
Trifluralin	Not Detected	ug/L	0.094		
Trace Organics					
1,4-dichlorobenzene	Not Detected	ug/L	0.2		
1-methylnaphthalene	Result Not Usable	ug/L	R		
2,2',4,4'-tetrabromodiphenyl ether	Not Detected	ug/L	0.3		
2,6-dimethylnaphthalene	Result Not Usable	ug/L	R		
2-methylnaphthalene	Result Not Usable	ug/L	R		
3,4-dichlorophenyl isocyanate	Not Detected	ug/L	1.6		
3-beta-coprostanol	Not Detected	ug/L	1.6		
3-methyl-1h-indole (skatol)	Not Detected	ug/L	0.2		
3-tert-butyl-4-hydroxyanisole (bha)	Not Detected	ug/L	0.2		
4-cumylphenol	Result Not Usable	ug/L	R		
4-n-octylphenol	Result Not Usable	ug/L	R		
4-nonylphenol monoethoxylate - total (np1eo)	Result Not Usable	ug/L	R		
4-octylphenol diethoxylate (op2eo)	Result Not Usable	ug/L	R		

Chemical	Result ^a	Units	Laboratory Detection Limit	Drinking Water Standards	
				MCL ^b	SMCL ^c
4-octylphenol monoethoxylate (op1eo)	Result Not Usable	ug/L	R		
4-tert-octylphenol	Result Not Usable	ug/L	R		
5-methyl-1h-benzotriazole	Not Detected	ug/L	1.6		
acetophenone	Result Not Usable	ug/L	R		
acetyl-hexamethyl-tetrahydro-naphthalene (ahtn)	Not Detected	ug/L	0.2		
anthracene	Result Not Usable	ug/L	R		
anthraquinone	Not Detected	ug/L	0.2		
atrazine	Not Detected	ug/L	0.2	3.0	
benz[a]pyrene	Result Not Usable	ug/L	R	0.2	
benzophenone	Result Not Usable	ug/L	R		
beta-sitosterol	Not Detected	ug/L	1.6		
beta-stigmastanol	Not Detected	ug/L	1.7		
bis-(2-ethylhexyl) phthalate (dehp)	Not Detected	ug/L	2	6	
bisphenol a	Result Not Usable	ug/L	R		
bromacil	Not Detected	ug/L	0.8		
bromoform	Not Detected	ug/L	0.2	80	
caffeine	Result Not Usable	ug/L	R		
camphor	Not Detected	ug/L	0.2		
carbaryl	Not Detected	ug/L	0.2		
carbazole	Not Detected	ug/L	0.2		
chlorpyrifos	Not Detected	ug/L	0.2		
cholesterol	Not Detected	ug/L	1.6		
cotinine	Not Detected	ug/L	0.8		
diazinon	Not Detected	ug/L	0.2		
dichlorvos	Not Detected	ug/L	0.2		
diethoxynonylphenols- total (np2eo)	Result Not Usable	ug/L	R		
diethyl phthalate	Not Detected	ug/L	0.2		
d-limonene	Not Detected	ug/L	0.2		
fluoranthene	Result Not Usable	ug/L	R		
hexahydrohexamethyl cyclopentabenzopyran (hhcb)	Not Detected	ug/L	0.2		
indole	Not Detected	ug/L	0.2		
isoborneol	Not Detected	ug/L	0.2		
isophorone	Not Detected	ug/L	0.2		
isopropylbenzene (cumene)	Not Detected	ug/L	0.2		
isoquinoline	Not Detected	ug/L	0.2		
menthol	Not Detected	ug/L	0.2		
metalaxyl	Not Detected	ug/L	0.2		
methyl salicylate	Not Detected	ug/L	0.2		

Chemical	Result ^a	Units	Laboratory Detection Limit	Drinking Water Standards	
				MCL ^b	SMCL ^c
metolachlor	Not Detected	ug/L	0.2		
n,n-diethyl-meta-toluamide (deet)	Not Detected	ug/L	0.2		
naphthalene	Result Not Usable	ug/L	R		
para-nonylphenol total	Not Detected	ug/L	1.6		
p-cresol	Not Detected	ug/L	0.2		
pentachlorophenol	Result Not Usable	ug/L	R	1.0	
phenanthrene	Result Not Usable	ug/L	R		
phenol	Result Not Usable	ug/L	R		
prometon	Not Detected	ug/L	0.2		
pyrene	Result Not Usable	ug/L	R		
tetrachloroethylene	Not Detected	ug/L	0.4	5.0	
tri(2-butoxyethyl) phosphate	Not Detected	ug/L	0.2		
tri(2-chloroethyl) phosphate	Not Detected	ug/L	0.2		
tri(dichloroisopropyl) phosphate	Not Detected	ug/L	0.2		
tributyl phosphate	Not Detected	ug/L	0.2		
triclosan	Not Detected	ug/L	0.2		
triethyl citrate (ethyl citrate)	Not Detected	ug/L	0.2		
triphenyl phosphate	Not Detected	ug/L	0.2		
Veterinary Pharmaceuticals					
Chlortetracycline(total)	Not Detected	ug/L	0.02		
Erythromycin	0.11	ug/L	0.02		
Lincomycin	0.371	ug/L	0.02		
Monensin	0.194	ug/L	0.02		
Oxytetracycline	Not Detected	ug/L	0.02		
Ractopamine	0.079	ug/L	0.02		
Sulfachloropyridazine	Not Detected	ug/L	0.02		
Sulfadimethoxine	Not Detected	ug/L	0.02		
Sulfamerazine	Not Detected	ug/L	0.02		
Sulfamethazine	0.053	ug/L	0.02		
Sulfamethazole	Not Detected	ug/L	0.02		
Sulfamethoxazole	0.04	ug/L	0.02		
Sulfathiazole	0.051	ug/L	0.02		
Tetracycline	Not Detected	ug/L	0.02		
Tiamulin	0.05	ug/L	0.02		
Tylosin	Not Detected	ug/L	0.02		
Virginiamycin	0.162	ug/L	0.02		
Wastewater Pharmaceuticals					
Acetaminophen	Not Detected	ug/L	0.2		
Amphetamine	Not Detected	ug/L	0.2		
Azithromycin	Not Detected	ug/L	0.2		
Caffeine	Not Detected	ug/L	0.2		
Carbamazepine	Not Detected	ug/L	0.2		
Cotinine	Not Detected	ug/L	0.2		
DEET	Not Detected	ug/L	0.2		
Diphenhydramine	Not Detected	ug/L	0.2		

Chemical	Result ^a	Units	Laboratory Detection Limit	Drinking Water Standards	
				MCL ^b	SMCL ^c
Ibuprofen	Not Detected	ug/L	0.2		
Methamphetamine	Not Detected	ug/L	0.2		
Naproxen	Result Not Useable	ug/L	0.2		
Paraxanthine	Not Detected	ug/L	0.2		
Thiabendazole	Not Detected	ug/L	0.2		
Triclosan	Result Not Useable	ug/L	0.2		
Nitrogen Isotopes					
Nitrate (NO ₃) as N	36.5	(mg/L)	0.1		
$\delta^{15}N-NO_3$	7.65	(‰)	NR		
Ammonia (NH ₄) as N	Not Detected	(mg/L)	1		
$\delta^{15}N-NH_4$	NM	(‰)	NM		
$\delta^{18}O-NO_3$	12.2	‰ SMOW	NR		
Age Dating					
Piston Flow Model SF6 Recharge Age	30.05	years	1970 ^h		

Laboratory Results

Notes, Abbreviations and Units

Notes

Shading indicates that the chemical was detected above the MCL.

Footnotes

^aThe Results column shows a numeric value for the concentration of the chemical if the chemical was detected in the sample. The term "Not Detected" means that the chemical was not detected in the sample above the laboratory detection limit. The term "Result Not Usable" indicates that there were quality assurance or quality control problems with the laboratory analysis of that chemical and there are no results to report.

^bMaximum contaminant levels (MCLs) are the highest level of a contaminant that is allowed in drinking water. MCLs are enforceable standards.

^cNational Secondary Drinking Water Regulations (or secondary maximum contaminant levels [SMCLs]) are non-enforceable guidelines regulating contaminants that may cause cosmetic effects (such as skin or tooth discoloration) or aesthetic effects (such as taste, odor, or color) in drinking water. EPA recommends secondary standards to water systems but does not require systems to comply. However, states may choose to adopt them as enforceable standards.

^dAny fecal coliform-positive repeat sample or *E. coli*-positive repeat sample, or any total coliform-positive repeat sample following a fecal coliform-positive routine sample constitutes a violation of the MCL for total coliforms. For purposes of the public notification requirements, this is a violation that may pose an acute risk to health.

^eNo more than 5.0% samples total coliform-positive in a month. Every sample that has total coliforms must be analyzed for fecal coliforms; no fecal coliforms are allowed.

^fFive hormones (17-a-estradiol, 17-a-ethynyl-estradiol, 17-b-estradiol, Estriol, and Estrone) were analyzed by two laboratories. The detection limits for these chemicals were different at each laboratory.

^gEPA does not have a MCL level for perchlorate. The human health based standard calculated under Washington State Model Toxics Control Act (MTCA) Cleanup Levels and Risk Calculation (CLARC) tool using Method B is 11ug/L.

^hThe SF6 recharge dating limit is around 1970.

Abbreviations

MCL - Maximum Contaminant Level

MTCA - Model Toxics Control Act

ND - Analysis not done

NM - Insufficient nitrate to complete analysis

NR - Not relevant. The result is a calculated value.

SMCL - Secondary Maximum Contaminant Level

SMOW - standard mean of ocean water

TNTC - Too numerous to count

$\delta^{15}\text{N-NO}_3$ = Nitrogen isotopes of nitrate. Ratio of the nitrogen isotopes ^{15}N and ^{14}N in a specific sample using nitrate compared to a standard of known composition of ^{15}N and ^{14}N . This expressed as the parts per thousand (‰).

$\delta^{15}\text{N-HN}_4$ = Nitrogen isotopes of ammonia. Ratio of the nitrogen isotopes ^{15}N and ^{14}N in a specific sample using ammonia compared to a standard of known composition of ^{15}N and ^{14}N . This expressed as the parts per thousand (‰).

$\delta^{18}\text{O-NO}_3$ = Oxygen isotopes of nitrate. Ratio of the oxygen isotopes ^{18}O and ^{16}O in a specific sample using nitrate compared to a standard of known composition of ^{18}O and ^{16}O . This expressed as the parts per thousand (‰) standard mean of ocean water.

Units

CFU/100 ml = colony forming unit per 100 milliliters

MPN/100 ml = most probable number per 100 milliliters

ug/L = micrograms per liter

mg/L = milligrams per liter

‰ = parts per thousand difference from the atmospheric standard

Data Qualifiers

< = less than

J = The analyte was positively identified. The associated numerical value is an estimate.

R = The data are unusable for all purposes.