



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
REGION 10

1200 Sixth Avenue, Suite 900
Seattle, WA 98101-3140

OFFICE OF
WATER AND
WATERSHEDS

DEC 04 2015

Reply to Attn of: OWW-191

Patrick Clark
Staker Parson Companies
2350 South 1900 West Suite 100
Ogden, UT 83634

Re: Additional Monitoring Requirements for IMC Ten Mile under the National Pollutant Discharge Elimination System Multi-Sector General Permit, Permit Reference No. IDR053057

Dear Mr. Kinney:

The purpose of this letter is to notify you of a new monitoring requirement that must be implemented at your facility to maintain permit coverage under the U.S. Environmental Protection Agency's (EPA) 2015 Multi-Sector General Permit for Stormwater Discharges Associated with Industrial Activity (MSGP).

There is a new provision in the State of Idaho's certification of the MSGP:

"9.10.3.3 Monitoring of Discharges to Impaired Waters. ...For water bodies included on the states 303(d) list (Category 5 of the Integrated Report), identified as "cause unknown", the permittee must monitor for the pollutants listed in the cause comments section of the report (e.g., nutrients, metals, pesticides)." Follow the standard benchmark monitoring procedures outlined in the MSGP at Part 6.2.1.

Based on the information provided in your Notice of Intent (NOI), storm water from the IMC Ten Mile facility at 7070 Ten Mile Road in Meridian, Idaho (Facility) discharges into Tenmile Creek. The cause comments for Tenmile Creek indicate that nutrients are the cause. As a result, the following nutrient monitoring is required.

| Parameter | Target | Reference |
|------------------|---|--|
| Total Phosphorus | 0.1 mg/L May 1-Sept 30 0.35 mg/L Oct 1- April 30 | Lower Boise River TMDL 2015 Total Phosphorus Addendum |

If you have any questions, please contact Margaret McCauley of my staff at mccauley.margaret@epa.gov or (206) 553-1772.

Sincerely,

Michael J. Lidgard, Manager
NPDES Permits Unit

cc: Lance Holloway, Idaho Department of Environmental Quality